



Fuel Requirements for Black Start Resources Additional Education / Impact Analysis

OC/MIC Special Session
6/11/2019




Current Level of Fuel Assurance for Existing Black Start Resources in PJM

PJM Black Start Fuel Assurance Breakdown

Non-Fuel Assured (Gas-to-Start)
6.3%

Non-Fuel Assured
24.7%




**Percent
by Unit Count**

Fuel Assured
53.2%

Hydro
15.8%

Non-Fuel Assured (Gas-to-Start)
6.8%

Non-Fuel Assured
37.7%




**Percent
by MW**

Fuel Assured
37.8%

Hydro
17.7%




PJM Fuel Assurance Breakdown by TO Zone





System Restoration Impact Analysis

How Black Start Units are Used



Start-up Black Start units

Energize cranking paths from Black Start (BS) to Critical Load (CL)

High voltages need to be controlled to avoid tripping or damaging equipment

- Reactive capabilities of online generators
- Non-generator reactive devices such as reactors, svc, etc
- Addition of load

Additional generation is brought online to support the building of cranking paths, voltage control, load pick-up, frequency, and reserves

Primary cranking paths

- Typically the shortest electrical path (least amount of line charging) from BS to CL
- Shortest electrical path may not have the least number of substations or lines

Alternate cranking paths

- Typically have increased line charging & higher line voltages
- **Typically require additional generation or load to control voltages which increases restoration times**

Analysis based on a sample of TO zones (4) with non-fuel assured black start sites and a different range of TO zone sizes

Impact of non fuel-assured gas black start units quantified by assessing incremental change in per unit value from primary cranking paths to alternate cranking paths for substations, transmission lines, generators, line charging, and load pick-up

Steady state/dynamic studies performed to validate alternate cranking paths

Alternate cranking paths and estimated times to energize buses and lines were provided by Transmission Owners

Projected incremental change in restoration times based on additional restoration complexity

A subset of non-fuel assured black start sites are unavailable due to a gas pipeline issue

Unavailable non-fuel assured gas black start sites replaced by another black start site that may or may not be fuel assured

All critical loads are available


All cranking paths have been assessed and cleared

All equipment/communications are available for SCADA control


Amount of time to energize the following assumed to be the same for each attribute for primary and alternate paths: Lines, Substations, Units, Load

Primary Cranking Paths

Cranking Path	Substations	Lines	Generators	Line Charging	Load
Primary Path 1: BS 1 to CL 1	2	4	1	50	0
Primary Path 2 : BS 2 to CL 2	3	4	1	20	0



Per Unit					
Cranking Path	Substations	Lines	Generators	Line Charging	Load
Primary Path 1: BS 1 to CL 1	1.0	1.0	1.0	1.0	1.0
Primary Path 2 : BS 2 to CL 2	1.0	1.0	1.0	1.0	1.0




Primary Cranking Paths represent existing paths

Alternate Cranking Path Example 1: Load Pick-up

Cranking Path	Substations	Lines	Generators	Line Charging	Load
Primary Path 1: BS 1 to CL 1	2	4	1	50	0
Alternate Path 1: BS 2 to CL 1	3	5	1	100	25

Per Unit					
Cranking Path	Substations	Lines	Generators	Line Charging	Load
Primary Path 1: BS 1 to CL 1	1.0	1.0	1.0	1.0	1.0
Alternate Path 1: BS 2 to CL 1	1.5	1.3	1.0	2.0	25.0




In this example, additional load is required to control voltage issues



Alternate Cranking Path Example 2: Additional Generation


Cranking Path	Substations	Lines	Generators	Line Charging	Load
Primary Path 1: BS 1 to CL 1	2	4	1	50	0
Alternate Path 2: BS 2 to CL 1	4	7	2	65	0

Per Unit					
Cranking Path	Substations	Lines	Generators	Line Charging	Load
Primary Path 1: BS 1 to CL 1	1.0	1.0	1.0	1.0	1.0
Alternate Path 2: BS 2 to CL 1	2	1.8	2.0	1.3	1.0



In this example, additional generation is required to control voltage issues


Alternate Cranking Path Example 3: Load Pick-up & Additional Generation




Cranking Path	Substations	Lines	Generators	Line Charging	Load
Primary Path 1: BS 1 to CL 1	2	4	1	50	0
Alternate Path 3: BS 2 to CL 1	4	7	2	65	30

Per Unit					
Cranking Path	Substations	Lines	Generators	Line Charging	Load
Primary Path 1: BS 1 to CL 1	1.0	1.0	1.0	1.0	1.0
Alternate Path 3: BS 2 to CL 1	2.0	1.8	2.0	1.2	30.0

In this example, additional generation and load pick-up is required to control voltage issues




1. Red line represents the required number units or buses or lines needed for primary cranking paths in per unit values
2. Bars indicate the required number of units or buses or lines for alternate cranking paths in per unit values
3. Bars above the red line indicate an increase in the required number of units or buses or lines for alternate cranking paths



1. Red line represents the amount of line charging(MVAR) and load pick-up(MW) for primary cranking paths in per unit values
2. Bars indicate the amount of line charging(MVAR) and load pick-up(MW) for alternate cranking paths in per unit values
3. Bars above the red line indicate an increase in the amount of line charging(MVAR) or load pick-up(MW) alternate cranking paths


Average/Minimum/Maximum Incremental Change by Attribute



Red line represents the number of units, buses, lines or load needed for primary cranking paths in per unit values

Incremental Restoration Time Change Concept

Time Change Ranges



Average time increase per cranking path ranged from 5.1 hours to 10.9 hours, but there were scenarios with high and low range times significantly higher



Analysis Results Summary

Almost all alternate paths resulted in increased restoration complexity

- Increased restoration complexity results in increased restoration times

Approximately 10% of alternate paths failed, primarily due to stability studies, requiring more complex alternate paths

Average incremental time increase per cranking path ranged from approximately 5 hours to 11 hours, but there were some scenarios with significantly higher time ranges

- Applied to cranking paths across TO zones with non-fuel assured black start resources, these time ranges could be significant



Fuel Assurance Requirements for Black Start Resources Preliminary Cost Impact



Black Start Fuel Assurance Projected Cost Impact Assumptions

Analyzed current and projected Black Start Resources as of 2020/2021 DY

Black Start Units without onsite fuel storage

- Additional projected costs for onsite fuel (conversion/storage)

Black Start Units requiring changes to startup fuel

- Additional projected costs to add capability to start with onsite fuel

No additional capital cost for existing Black Start Units with onsite fuel and onsite fuel start capability

Conversion capital costs based on estimates provided via 2018 RTO RFP

- Projected costs scaled to number of units per site and unit size



Black Start Fuel Assurance - Projected Cost Impact

\$513M

- Estimated Capital Cost to convert all non fuel assured black start units to black start fuel assured

\$156M

- Increase in Annual Black Start Revenue Requirements




Fuel Requirements for Black Start Resources Preliminary Cost Projections

Level of Fuel Assurance	Capital Cost to convert Black Start fuel assured units	Increase in Annual Revenue Requirement for Capital Recovery Period <i>(Note: Current BS Annual Revenue Requirement = \$65M/yr.)</i>
All black start resources allocated to a TO zone must be fuel assured	\$513M	\$156M/yr.
50% of black start resources allocated to a TO zone must be fuel assured	\$177M	\$56M/yr.
Minimum of two black start resources allocated to the TO zone at separate sites must be fuel assured	\$103M	\$30M/yr.




Projected Capital Costs Incremental Amount Above Annual Revenue Requirement






Fuel Assurance Cost Impact

Impact Of Black Start Fuel Assurance on Current Annual Revenue Requirements for PJM





PJM Fuel Assurance Breakdown by TO Zone



Note: Costs represent the incremental cost per MWh of black start service for fuel assurance conversions