



Reliability Analysis Update

Transmission Expansion Advisory
Committee
August 8, 2019

- The following definitions explain the basis for excluding flowgates and/or projects from the competitive planning process and designating projects to the incumbent Transmission Owner.
- Flowgates/projects excluded from competition will include the underlined language on the corresponding slide.
 - Immediate Need Exclusion: Due to the immediate need of the violation (3 years or less), the timing required for an RTEP proposal window is infeasible. As a result, the local Transmission Owner will be the Designated Entity. - Operating Agreement, Schedule 6 § 1.5.8(m)
 - Below 200kV Exclusion: Due to the lower voltage level of the identified violation(s), the driver(s) for this project are excluded from the competitive proposal window process. As a result, the local Transmission Owner will be the Designated Entity - Operating Agreement, Schedule 6 § 1.5.8(n)
 - FERC 715 (TO Criteria) Exclusion: Due to the violation need of this project resulting solely from FERC 715 TO Reliability Criteria, the driver(s) for this project are excluded from the competitive proposal window process. As a result, the local Transmission Owner will be the Designated Entity - Operating Agreement, Schedule 6 § 1.5.8(o)
 - Substation Equipment Exclusion: Due to identification of the limiting element(s) as substation equipment, the driver(s) for this project are excluded from the competitive proposal window process. As a result, the local Transmission Owner will be the Designated Entity - Operating Agreement, Schedule 6 § 1.5.8(p)



2019 RTEP Analysis Update

May 22, 2019

- Preliminary 2024 results posted
 - Summer Baseline and N-1 Thermal
 - Summer Generator Deliverability

July 3, 2019

- 2019 Proposal Window No.1 opened


Friday, September 6, 2019

- 2019 Proposal Window No.1 closes

Overview of 2024 Results


Total of 136 flowgates identified

- 102 to be included in the window
 - 63 in the PJM Mid-Atlantic Region
 - 33 in PJM West Region
 - 6 in the PJM South Region
- 34 flowgates excluded
 - 9 due to the below 200 kV exclusion
 - 25 due to the substation equipment exclusion
- 19 require additional review




2024 Summer conditions

- 67 included violations
 - 45 baseline and single contingency
 - 6 generation deliverability
 - 16 N-1-1




2024 Winter conditions

- 22 included violations
- 6 generation deliverability
- 16 N-1-1



2024 Light Load conditions


- 13 N-1 Voltage Drop violations






2024 Analysis Violations

| Voltage Region | Window Status | | | Substation Equipment Exclusion |
|--------------------|---------------|------------|---------------------------|--------------------------------------|
| | TBD | Included | Below 200 kV Exclusion | |
| 69 kV | | | | |
| PJM MA | | 57 | 4 | |
| PJM South | 6 | | | |
| PJM West | 12 | | | |
| 115 kV | | | | |
| PJM MA | | | | 2 |
| PJM South | 1 | | | |
| 138 kV | | | | |
| PJM MA | | 6 | | |
| PJM West | | 29 | 5 | 23 |
| 230 kV | | | | |
| PJM South | | 6 | | |
| 345 kV | | | | |
| PJM West | | 4 | | |
| Grand Total | 19 | 102 | 9 | 25 |



102 flowgates are window eligible




63 Eligible Flowgates

- 5 Thermal
- 6 Generation Deliverability
- 52 Voltage

6 Flowgates Excluded from Window

- 4 Below 200kV
- 2 Substation Equipment






2019 RTEP Proposal Window 1 – Mid-Atlantic Results

PJM Mid-Atlantic Region

| Voltage Class Criteria Test | Proposal Window Status | | |
|--------------------------------|------------------------|---------------------------|--------------------------------------|
| | Included | Below 200 kV Exclusion | Substation Equipment Exclusion |
| 69 kV | 57 | 4 | |
| GD | 6 | 1 | |
| N1-T | 5 | 1 | |
| N1-VD | 29 | | |
| N1-VM | 17 | 2 | |
| 115 kV | | | 2 |
| N2-T | | | 2 |
| 138 kV | 6 | | |
| N1-VD | 4 | | |
| N1-VM | 2 | | |
| Grand Total | 63 | 4 | 2 |




6 Eligible Flowgates

- On the 230 kV system
- 2 Generation Deliverability
- 4 Thermal

7 Flowgates Pending Review

- 6 Thermal
- 1 Generation Deliverability






2019 RTEP Proposal Window 1 – South Results

PJM South Region

| Voltage Class Criteria Test | Proposal Window Status | |
|--------------------------------|------------------------|----------|
| | Included | TBD |
| 69 kV | | 6 |
| N2-T | | 6 |
| 115 kV | | 1 |
| GD | | 1 |
| 230 kV | 6 | |
| GD | 2 | |
| N1-T | 1 | |
| N2-T | 3 | |
| Grand Total | 6 | 7 |



33 Eligible Flowgates


- All on the 230 kV system
- All 4 Thermal

28 Excluded Flowgates

- 5 Below 200 kV
- 23 Substation Equipment

12 Flowgates Pending Review

- 6 Thermal
- 1 Generation Deliverability






2019 RTEP Proposal Window 1 – West Results

PJM West Region

| Voltage Class Criteria Test | Included | Proposal Window Status | | TBD |
|--------------------------------|-----------|---------------------------|--------------------------------------|-----------|
| | | Below 200 kV Exclusion | Substation Equipment Exclusion | |
| 69 | | | | 12 |
| N2-T | | | | 12 |
| 138 | 29 | 5 | 23 | |
| GD | | 3 | 9 | |
| N1-T | | | 8 | |
| N2-T | | 2 | 6 | |
| N2-VD | 10 | | | |
| N2-VM | 19 | | | |
| 345 | 4 | | | |
| GD | 4 | | | |
| Grand Total | 33 | 5 | 23 | 12 |



Dominion End of Life Criteria



Dominion Transmission Zone: Baseline Line #569 Rebuild (End of Life Criteria)

Process Stage: First Review

Criteria: End of Life

Assumption Reference: FERC 715

Model Used for Analysis: 2018 Series 2023 Summer RTEP

Proposal Window Exclusion: FERC 715 (TO Criteria)

Problem Statement:

The 500 kV Line #569, from Loudoun to Morrisville, is approximately 32 miles long and 1.3 miles of this line is constructed on CORTEN structures. A third party study (Quanta) has determined that these structures are at the end of their useful life.

Reliability studies indicate that retiring Line #569 will result in thermal overloads in accordance with P6 NERC criteria violations.

Proposed Solution:

Rebuild the 1.3 mile section of Line #569 with single-circuit 500 kV structures at the current 500 kV standard. This will increase the rating of Line #569 to 3424 MVA.

Alternative: No feasible alternatives.


Estimated Project Cost: \$4.5 M

Required In-Service Date: As Soon As Possible

Projected In-Service Date: 12/31/2024

Project Status: Conceptual

| COLOR | VOLTAGE | TRANSMISSION LINE NUMBER |
|--------|---------|-------------------------------|
| Green | 500 KV. | 500 thru 599 |
| Blue | 230 KV. | 200 thru 299 & 2000 thru 2099 |
| Red | 115 KV. | 1 thru 199 |
| Orange | 138 KV. | AS NOTED |
| Cyan | 69 KV. | AS NOTED |



First Review

Baseline Reliability Projects



Re-evaluation of the B1690 (MCRP) Project

B1690 (MCRP) project timeline:

- The B1690 was initially proposed – 3Q of 2011.
- The B1690 filing with the New Jersey Board of Public Utilities – 3Q of 2016
- B1690 Evidentiary Hearings with the New Jersey Office of Administrative Law – 2Q - 3Q of 2017
- New Jersey Office of Administrative Law decision – 1Q of 2018
- New Jersey Board of Public Utilities decision – 2Q of 2018
- PJM Re-evaluation of need – 3Q of 2018 (presented at September 2018 TEAC)
- PJM and FirstEnergy development of Alternatives – 4Q 2018 through 1Q 2019
- FirstEnergy meetings with Federal, State, and Local stakeholders – 2Q through 3Q of 2019

JCP&L Transmission Zone: Baseline Monmouth County 34.5 kV Solution

Process Stage: First Review

Criteria: PJM and FirstEnergy Planning Criteria

Assumption Reference: Voltage Drop, Voltage Magnitude, and Loss of Load

Model Used for Analysis: 2018 Series 2021 and 2023 Summer RTEP


Proposal Window Exclusion: Immediate Need

Problem Statement:

- Severe voltage drop violation on the Red Bank bus for towerline outage loss of Atlantic – Red Bank 230 kV (T2020 & S1033) circuits.
- Severe voltage drop violation on the Red Bank bus for N-1-1 contingency loss of Atlantic – Red Bank 230 kV (T2020 & S1033) circuits.
- Several JCP&L 34.5 kV lines severely overloaded for the towerline outage loss of Atlantic – Red Bank 230 kV (T2020 & S1033) circuits requiring dynamic cascade analysis.
 - FirstEnergy performed dynamic cascade analysis
 - The dynamic cascade analysis resulted in tripping significant number of 34.5 kV lines and loss of >520 MW load due to voltage collapse.

Existing Facility Rating: N/A

Continued on next slide...



JCP&L Transmission Zone: Baseline Monmouth County 34.5 kV Solution

Proposed Solution:

Construct seven new 34.5 kV circuits on existing pole lines (total of 53.5* miles):

- Oceanview to Allenhurst 34.5 kV (4.0 Miles) – b1690.1
- Atlantic to Red Bank 34.5 kV (12.0 Miles) – b1690.2
- Freneau to Taylor Lane 34.5 kV (6.5 Miles) – b1690.3
- Keyport to Belford 34.5 kV (6.0 Miles) – b1690.4
- Red Bank to Belford 34.5 kV (5.0 Miles) – b1690.7
- Werner to Clark Street (7.0 Miles) – b1690.8
- Atlantic to Freneau (13.0 Miles) – b1690.9

Rebuild/Reconductor two 34.5 kV circuits (total of 5.5 miles):

- Atlantic to Camp Woods Switch Point (3.5 Miles) – b1690.5
- Allenhurst to Elberon (2.0 Miles) – b1690.6

Install 2nd 115-34.5 kV Transformer at Werner Substation – b1690.10

Estimated Project Total Cost: \$175M


Alternatives:

1. 230 kV Transmission Line with Steel Monopoles:
 - Along Garden State Parkway - Estimated Cost \$284M
 - Along NJ Route 35 - Estimated Cost \$329M
2. 34.5 kV Transmission Line construction with:
 - Remedial Action Scheme (RAS) - Estimated Cost \$303M
 - Battery Installations - Estimated Cost \$401M

Required In-Service: Immediate Need

Project Status: Conceptual

* - 44.1 miles will be converting existing single circuit to double circuit 34.5 kV construction; 9.4 miles will be adding 34.5 kV circuit to existing distribution pole lines



- Preliminary discussion of proposals received

Questions?



2019

- TEAC meetings are the following Thursdays in 2019
- **1/10, 2/7, 3/7, 4/11, 5/16, 6/13, 7/11, 8/8, 9/12, 10/17, 11/14, 12/12.**

- V1 – 08/01/2019 – Original slides posted
- V2 – 08/02/2019 – Added Reliability Analysis slides #4 through #16