

# Dominion Supplemental Projects

Transmission Expansion Advisory  
Committee  
November 1, 2022

# Needs

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

# Dominion Transmission Zone: Supplemental Customer Load Request

**Need Number:** DOM-2022-0054

**Process Stage:** Need Meeting 11/01/2022

**Project Driver:** Customer Service


**Specific Assumption References:**

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.

**Problem Statement:**

DEV has submitted a DP Request for a new substation (Lunar) in Loudoun County with a total load in excess of 100MW. Requested in-service date is 3/01/2024.

Initial In-Service Load	Projected 2027 Load
Summer: 12.0 MW	Summer: 211.0 MW



# Dominion Transmission Zone: Supplemental Customer Load Request

**Need Number:** DOM-2022-0055

**Process Stage:** Need Meeting 11/01/2022

**Project Driver:** Customer Service


**Specific Assumption References:**

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.

**Problem Statement:**

DEV has submitted a DP Request for a new substation (Apollo) in Loudoun County with a total load in excess of 100MW. Requested in-service date is 1/1/2025.

Initial In-Service Load	Projected 2027 Load
Summer: 27.0 MW	Summer: 176.0 MW



# Dominion Transmission Zone: Supplemental Customer Load Request

**Need Number:** DOM-2022-0056

**Process Stage:** Need Meeting 11/01/2022

**Project Driver:** Customer Service


**Specific Assumption References:**

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.

**Problem Statement:**

DEV has submitted a DP Request for a new substation (Pluto) in Loudoun County with a total load in excess of 100MW. Requested in-service date is 11/1/2025.

Initial In-Service Load	Projected 2027 Load
Summer: 54.0 MW	Summer: 139.0 MW



# Dominion Transmission Zone: Supplemental Operational Flexibility and Efficiency

**Need Number:** DOM-2022-0057

**Process Stage:** Need Meeting 11/01/2022

**Project Driver:** Operational Flexibility and Efficiency


**Specific Assumption References:**

See details on Operational Flexibility and Efficiency in Dominion’s Planning Assumptions presented in December 2021.

**Problem Statement:**

Near-term planning studies and Dominion Energy Operations Engineering studies have identified overloads on 230 kV Line #2172 (Brambleton – Evergreen Mills) for the loss of Line #2183 (Brambleton – Poland Road).

The Dominion Energy Operations team needs a temporary solution to avoid this overload on Line #2172 and accordingly provide flexibility for future construction outages.



# Solutions

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

# Dominion Transmission Zone: Supplemental Equipment Material Condition, Performance and Risk

**Need Number:** DOM-2022-0051

**Process Stage:** Solution Meeting 11/01/2022

**Previously Presented:** Need Meeting 09/06/2022


**Project Driver:** Equipment Material Condition, Performance and Risk

**Specific Assumption References:**

See details on Equipment Material Condition, Performance and Risk in Dominion’s Planning Assumptions presented in December 2021.

**Problem Statement:**

Dominion Energy has identified a need to replace five 230kV breakers (L912, 206812, SX1212, SX12T235 & 23512) and six disconnect switches (SX1214, SX1215, SX1218, 23518, 23514, & 23515) at Clover Substation. These breakers and switches were manufactured in 1993 and are at end of life. Additionally, there has been an increase in maintenance issues and difficulties in obtaining spare parts.





# Dominion Transmission Zone: Supplemental Replace Clover Substation Breakers and Switches


**Need Number:** DOM-2022-0051

**Process Stage:** Solution Meeting 11/01/2022

## **Proposed Solution:**

Replace the following 230kV breakers and switches at Clover Substation -

- Two breakers (L912 and 206812) with 3000 amp 50kA breakers.
- Three breakers (SX1212, SX12T235 & 23512) with 4000 amp 63kA breakers.
- Six disconnect switches (SX1214, SX1215, SX1218, 23518, 23514, & 23515) with 4000 amp switches.



**Estimated Project Cost:** \$ 2.75M

**Alternatives Considered:** None

**Projected In-Service Date:** 6/01/2023

**Project Status:** Engineering

**Model:** 2027 RTEP

# Dominion Transmission Zone: Supplemental Equipment Material Condition, Performance and Risk

**Need Number:** DOM-2022-0052

**Process Stage:** Solution Meeting 11/01/2022

**Previously Presented:** Need Meeting 09/06/2022

**Project Driver:** Equipment Material Condition, Performance and Risk


**Specific Assumption References:**

See details on Equipment Material Condition, Performance and Risk in Dominion’s Planning Assumptions presented in December 2021.

**Problem Statement:**

Dominion Energy has identified a need to replace 230kV equipment at North Anna substation:

- Breaker 25502 at end of life, manufactured in 1993
- Center breaker switches H304, H305, 25504 and 25505 at end of life about 20 years old
- Line #255 wave trap at end of life 21 years old
- Transformer #3 high side circuit switcher H302 due to fault interruption requirements



# Dominion Transmission Zone: Supplemental Replace North Anna Substation Breakers and Switches

**Need Number:** DOM-2022-0052

**Process Stage:** Solution Meeting 11/01/2022

## **Proposed Solution:**

Replace the following 230kV equipment at North Anna Substation -

- Breaker 25502 with a 3000 amp 63kA breaker.
- Center breaker switches H304, H305, 25504 and 25505 with 3000 amp switches
- Line #255 wave trap with a 3000 amp wave trap
- Transformer #3 high side circuit switcher H302 with a 1200 amp 40kAIC circuit switcher



**Estimated Project Cost:** \$ 2.36M

**Alternatives Considered:** None

**Projected In-Service Date:** 8/30/2023

**Project Status:** Engineering

**Model:** 2027 RTEP

# Dominion Transmission Zone: Supplemental Equipment Material Condition, Performance and Risk

**Need Number:** DOM-2022-0053

**Process Stage:** Solutions Meeting 11/01/2022

**Previously Presented:** Need Meeting 09/06/2022

**Project Driver:** Equipment Material Condition, Performance and Risk

## **Specific Assumption References:**


See details on Equipment Material Condition, Performance and Risk in Dominion's Planning Assumptions presented in December 2021.

## **Problem Statement:**

Davis TX#2 is a 168 MVA, 230/69/13.2 kV transformer bank that was manufactured in 1990. This transformer bank has been identified for replacement based on the results of Dominion's transformer health assessment (THA) process. Detailed drivers include:

- Age (>30 years old).
- Reduced BIL ratings (2 levels below standard).
- Tertiary winding design not meeting current MVA requirement for loading.
- Degraded porcelain type bushings.

Additionally, a protection scheme update at Davis requires the addition of multiple external bushing CT's to the low-voltage and high-voltage bushings which will compromise strike distances on the bushings. The ability to add more internal CT's was not considered when the transformer was ordered in 1989.



# Dominion Transmission Zone: Supplemental Replace Davis TX#2 - DEV

**Need Number:** DOM-2022-0053

**Process Stage:** Solution Meeting 11/01/2022

**Proposed Solution:**

Replace Davis TX#2 with a new three-phase, 230/69/13.2 kV, 168 MVA unit.  
Include other ancillary equipment (arresters, switches, relays, etc.) as needed.

**Estimated Project Cost:** \$4.5 M


**Alternatives Considered:**

None

**Projected In-service Date:** 06/30/2023

**Project Status:** Engineering

**Model:** 2027 RTEP



# Appendix

# High level M-3 Meeting Schedule

Assumptions	Activity	Timing
	Posting of TO Assumptions Meeting information	20 days before Assumptions Meeting
	Stakeholder comments	10 days after Assumptions Meeting
Needs	Activity	Timing
	TOs and Stakeholders Post Needs Meeting slides	10 days before Needs Meeting
	Stakeholder comments	10 days after Needs Meeting
Solutions	Activity	Timing
	TOs and Stakeholders Post Solutions Meeting slides	10 days before Solutions Meeting
	Stakeholder comments	10 days after Solutions Meeting
Submission of Supplemental Projects & Local Plan	Activity	Timing
	Do No Harm (DNH) analysis for selected solution	Prior to posting selected solution
	Post selected solution(s)	Following completion of DNH analysis
	Stakeholder comments	10 days prior to Local Plan Submission for integration into RTEP
	Local Plan submitted to PJM for integration into RTEP	Following review and consideration of comments received after posting of selected solutions

# Revision History

10/25/2022 – V1 – Original version posted to pjm.com

10/31/2022 – V2 – Updated wording on slides 10 & 11.