



Regulation Performance Metrics

Regulation Market Issues Senior Task Force

July 19, 2016

Danielle Croop, senior engineer –
Performance Compliance

Average 'Marginal' RegD Performance Score					
	On Peak	Off Peak	Excursion	Non-Excursion	Non-Excursion On Peak
Feb	0.79	0.80	0.81	0.79	0.79
Mar	0.83	0.91	0.93	0.82	0.78
Apr	0.82	0.90	0.94	0.80	0.76
May	0.81	0.90	0.93	0.79	0.75
Jun	0.86	0.93	0.94	0.86	0.83
Jul	0.84	0.93	0.94	0.84	0.80

Maximum 'Marginal' RegD Performance Score					
	On Peak	Off Peak	Excursion	Non-Excursion	Non-Excursion On Peak
Feb	0.95	0.92	0.95	0.92	0.86
Mar	0.95	0.94	0.95	0.94	0.87
Apr	0.95	0.94	0.95	0.94	0.88
May	0.95	0.93	0.95	0.93	0.87
Jun	0.95	0.94	0.95	0.94	0.90
Jul	0.95	0.94	0.95	0.94	0.90

* Data through Jul 12, 2016



Regulation Market Composition

MW	Steam	Hydro	CT	Energy Storage	DSR	Total
Regulation A Qualified	3,757	1,013	1284	0	1	6055
Avg. Performance Score	75%	83%	85%	NA	86%	
Regulation D Qualified	0	420	65	276	19	780
Avg. Performance Score	NA	77%	90%	95%	82%	
Requirement On-Peak						700
Requirement Off-Peak						525

* Data as of July 1